

Energy Consumption and Greenhouse Gas Emissions Reporting - for 2011																									
Please refer to notes to fiscal year. Press (UP or DN) to scroll down or up. Confirm representative 12 month period.																									
Month year to month year: January 2011 to December 2011																									
Type of Public Agency (Sector): Public Hospital																									
Agency Sub-sector: Public/Charitable																									
Please fill in the mandatory fields indicated in red, in addition to submitting data on your energy usage.																									
Facility Name: Anson General Hospital																									
Operation Name and/or Unique Identifier	Operation Type	Address	City	Fiscal Code	Total Floor Area of the Section Space in which Operation is Conducted	Average # Hours Per Week	Electricity	Natural Gas	Fuel Oil 1 & 2	Fuel Oil 4 & 5	Propane	Energy Type and Amount Purchased and Consumed in Natural Units	Coal	Wood	District Heating	Renewable?	If Yes, enter Emission Factor	District Cooling	Renewable?	If Yes, enter Emission Factor	Total (These columns will calculate when file is saved)	GHG Emissions (kg)	Energy Intensity (kg/m2)	Comments	
Anson General Hospital	Facilities used for hospital purposes	58 Anson Drive	Proquitt Falls	FOR LE0	51,000.00 Square feet	168	1,277,447.00000 kWh	205,496.00000 Cubic meter							41.60000 Giga Joule - steam or hot water	No	0.00000	40.15000 Giga Joule - district cooling	No	0.00000		2,437,244.17000	47.786	GHG derived and by hospital units	2,53076

